SOUTHWEST GAS CORPORATION P.O. Box 98510 Las Vegas, Nevada 89193-8510 Arizona Propane Tariff No. 1

## RULE NO. 8

Canceling

Each trailer must have outside make-up air vents.

## **POLICY ON TRAILER PARKS**

2.	Each	trailer	must	have	а	flexible	connector	of	а	minimum	length	of	36	inches
	betwe	en the	botton	n of the	e tr	railer and	d ground le	vel a	at t	the gas inle	et to the	tra	iler.	

Issued On October 18, 2005
Docket No. G-01551A-02-0425

Issued by John P. Hester Vice President

Effective October 18, 2005
Decision No. 68249